

Contents: **Release Notes**
Client: **EbV**

1 Update 2.2.43347, Relay V2.2 Rev. 53 dated 14 October 2026

Update available for:

heatapp! base	heatapp! base T2B	heatapp! gateway
heatcon! EC 1351	heatcon! EC 1321	heatapp! Zentrale

2 Contents of the update

- **Bug fixes**

- Fixed an MQTT error causing the connection to be interrupted.
- Extension of parameter sharing for Modbus / MQTT / Home Assistant

3 Security advice

It is generally advisable to back up your data **before** carrying out an update. To do this, select 'Settings > System > System Management' in the app and create a backup on a USB stick plugged into the heatcon! EC/heatapp! base/heatapp! base T2B.

Note: It is not possible to back up the heatapp! gateway.

Carry out the updates after backing up your data. **Under no circumstances should you disconnect the devices from the power supply whilst the update is in progress.** Depending on the size of the system and the speed of your internet connection, the updates may take up to 20 minutes and are only complete once the LED(s) are lit a steady dark green again.

4 Update path for manual execution

Settings > System > System Management

We hope you enjoy using your system.

Your EbV team

If you have any questions, please contact our technical support

Email: Support@ebv-gmbh.de

Telephone: 02736 44 305 900